



Plan to replace this cable. Not only does it have 2 apartments running through it, there is no CPC.

Apartment 32 A 1P Type C MCB

Live (Out)

Neutral (Out)

Grouped Neutral



Neutral (In) Neutral (Out)

Live (In)

Live (Out)

63 A 3P Type C MCB (feeds 3 separate apartments)

Earth connection cannot be verified. It is buried into the concrete floor however the rebar in the building may not be continuous... This is the only attempt at an earth I have found in this building block

There is no earth conductors / armoured cables anywhere in the building

Incoming 3-phase, 4-wire (3ph + N) supply Core colours are meaningless throughout (comes in and then out to more apartments in the block)