

Block of 3 garages within wooden structure – 2 garages require EV charging points that are fed from separate semi detached dwellings.

Current situation:

1. UK Power networks have been asked to confirm whether 2 properties are connected to the same earthing system.

Question

2. Would bonding with 10mm between the 2 new CU's be an acceptable way of reducing the simultaneous contact voltage whether they are part of the same earthing system or not?

